



Nr. DoP F031

1. Product- type:
- LIYY ALARM CABLE
 - GATE AUTOMATION C-4 (U0=400 V)
 - E035SCS2 - BUS
 - FR2OR (DIN 47100)
 - FR2OR (UNEL 00722)
 - FR2OR (UNEL 00722 S G/V)
 - LIYY (DIN 47100)
 - YSLY-JZ/OZ (EN 50334)
 - YSLY-JB/OB (HD308 S2)
 - YSLY-JZ/OZ 0.6/1 kV (EN 50334)

2. Intended use(s): Supply of electricity in buildings and other civil engineering works with the purpose of limiting the generation and spread of fire and smoke.

3. Manufacturer: Prospecta S.r.l.
Via Giacomo Balla, 24
42025 - Cavriago (RE) - Italy
Tel. 0522-946182 / 0522-946183
e-mail: export-cs@prospectasrl.it

4. System of AVCP: AVCP 3

5. Notified body: 2479

6. Declared performance:

Essential requirements	Performances	Harmonised standards
Reaction to fire	Eca	EN 50575:2014 + EN 50575/A1:2016
Release of dangerous substances	NPD	

The performance of the above mentioned product is in conformity with the set of declared performance/s. The issue of this declaration of performance, in accordance with Regulation (EU) No 305/2011, is under the sole responsibility of the manufacturer identified herewith.

Cavriago, 29/06/2017

Signed on behalf of and in the name of the manufacturer by

R&D Manager
Eng. Davide Bagnacani